


NOTES:

1. MINIMUM CONCRETE STRENGTH SHALL BE 4000PSI AT 28 DAYS.
2. COMPACTED STONE BASE SHALL COMPLY WITH NYSDOT ITEM 304.12, TYPE 2.
3. CROSS SLOPE GRADE SHALL BE AS SHOWN ON DETAIL WHENEVER POSSIBLE AND SLOPED TOWARDS ROAD PAVEMENT.
4. WELDED WIRE FABRIC SHALL COMPLY WITH NYSDOT SPECIFICATION 709-02
5. BROOM FINISH REQUIRED ON ALL SIDEWALKS.
6. CONTRACTOR MUST GRADE LAWN 2' FROM NEW SIDEWALK EDGE TO PROVIDE MOWABLE SLOPE AND RESTORE LAWN.

* 6" THICK AT DRIVEWAYS

TYPICAL SIDEWALK & CURB DETAIL

N.T.S.

 TOWN OF HENRIETTA	CONCRETE SIDEWALK AT CURB	
	SCALE: N.T.S.	
	DATE: 03/14/2012	
	RD-12b	